

## FY 2023 Annual operation report (Toyohashi City Biomass Utilization Center)

Items	Period	Apr. to June	July to Sept.	Oct. to Dec.	Jan. to Mar.	Total
	Number of days	91	92	92	91	366
Public sewage sludge volume	(m3)	30,937.5	34,267.7	37,212.8	39,078.5	141,496.6
	(m3/day)	340.0	372.5	404.5	429.4	386.6
Regional sewage system/Excrement purifying chamber sludge volume	(m3)	13,168.9	12,755.8	12,927.6	12,499.5	51,351.8
	(m3/day)	144.7	138.7	140.5	137.4	140.3
Garbage acceptance amount	(t)	3,813.0	3,825.7	3,625.3	3,776.5	15,040.5
	(t/day)	41.9	41.6	39.4	41.5	41.1
Generated power	(kWh)	1,816,928	1,822,607	1,910,449	1,531,660	7,081,644
	(kWh/day)	19,966	19,811	20,766	16,831	19,349
Amount of carbonized fuel transported	(t)	621.3	631.8	598.58	657.01	2,508.7
	(t/day)	6.8	6.9	6.5	7.2	6.9

Top: period total

Bottom: daily average