

FY 2024 Annual operation report (Toyohashi City Biomass Utilization Center)

Period		Apr. to June	July to Sept.	Oct. to Dec.	Jan. to Mar.	Total
Items						
Number of days		91	92	92	90	365
Public sewage sludge volume	(m3)	36,356.2	38,071.4	37,561.6	40,847.5	152,836.6
	(m3/day)	399.5	413.8	408.3	453.9	418.7
Regional sewage system/Excrement purifying chamber sludge volume	(m3)	13,055.6	12,959.6	13,302.1	12,565.5	51,882.7
	(m3/day)	143.5	140.9	144.6	139.6	142.1
Garbage acceptance amount	(t)	3,668.2	3,768.5	3,452.1	3,214.9	14,103.7
	(t/day)	40.3	41.0	37.5	35.7	38.6
Generated power	(kWh)	1,887,980	1,721,071	1,768,185	1,850,217	7,227,453
	(kWh/day)	20,747	18,707	19,219	20,558	19,801
Amount of carbonized fuel transported	(t)	596.11	569.74	516.08	588.09	2,270.02
	(t/day)	6.6	6.2	5.6	6.5	6.2

Top: period total
Bottom: daily average