

FY2025 Exhaust gas analysis results of carbonizing equipment and power generation facilities

【Regulation value】

Items	Carbonizing equipment	Power generation facilities
Dust	$\leq 0.08\text{g}/\text{m}^3\text{N}$	$\leq 0.04\text{g}/\text{m}^3\text{N}$
Sulfur oxides	$\leq 8.76$ (K value)	$\leq 8.76$ (K value)
Nitrogen oxides	250 ppm	200 ppm
Hydrogen chloride	$700\text{mg}/\text{m}^3\text{N}$	-
Dioxins	$1\text{ ng-TEQ}/\text{m}^3\text{N}$	-
Dioxins(dust)	$3\text{ ng-TEQ}/\text{g -dry}$	-
Mercury	$50\ \mu\text{g}/\text{m}^3\text{N}$	-

【Measurement value】 Carbonizing equipment

Sampling date	May-25	Aug-25	Nov-25	Jan-26
System classification	No. 1 system	No. 2 system	No. 1 system	No. 2 system
Dust (g/m <sup>3</sup> N)	0.005	0.025	-	-
Sulfur oxides (K value)	1.3	1.8	-	-
Nitrogen oxides (ppm)	110	55	95	89
Hydrogen chloride (g/m <sup>3</sup> N)	9.7	11.0	21	2.7
Dioxins (ng-TEQ/m <sup>3</sup> N)	0.00000065	0.00000054	-	-
Dioxins (dust) (ng-TEQ/g -dry)	0	0	-	-
Mercury ( $\mu\text{g}/\text{m}^3\text{N}$ )	15	21	13	4.7

【Measurement value】 Power generation facilities

Sampling date	May-25	Nov-25
Dust (g/m <sup>3</sup> N)	<0.004	-
Sulfur oxides (K value)	<0.03	-
Nitrogen oxides (ppm)	190	50