

FY 2025 Annual operation report (Toyohashi City Biomass Utilization Center)

Items	Period	Apr. to June	July to Sept.	Oct. to Dec.	Jan. to Mar.	Total
	Number of days	91	92	92	90	365
Public sewage sludge volume	(m3)	37,608.9	38,651.8	41,668.2	40,669.3	158,598.2
	(m3/day)	413.3	420.1	452.9	451.9	434.5
Regional sewage system/Excrement purifying chamber sludge volume	(m3)	13,109.8	12,785.1	12,812.6	12,654.6	51,362.1
	(m3/day)	144.1	139.0	139.3	140.6	140.7
Garbage acceptance amount	(t)	4,080.8	4,212.3	3,842.9	3,856.0	15,992.0
	(t/day)	44.8	45.8	41.8	42.8	43.8
Generated power	(kWh)	1,813,996	1,312,847	1,885,323	1,873,087	6,885,253
	(kWh/day)	19,934	14,270	20,493	20,812	18,864
Amount of carbonized fuel transported	(t)	567.02	480.44	645.49	658.90	2,351.85
	(t/day)	6.2	5.2	7.0	7.3	6.4

Top: period total

Bottom: daily average